



# Addendum #2

**IFB #2023-0001**

GENERAL CONTRACTOR FOR D. HAMILTON JACKSON TERRACE & ALPHONSO  
“PIGGY” GERARD COMPLEX REVITALIZATION  
ST. CROIX, U. S. VIRGIN ISLANDS

**This, and all addenda, must be acknowledged in your firm's proposal package.  
Please print a copy of this page and include it with your proposal package.  
If not acknowledged, your proposal will be removed from consideration.**

## ACKNOWLEDGMENT OF RECEIPT OF ADDENDA

The undersigned Respondent hereby acknowledges receipt of the following Addenda:

<b>Addendum Number</b>	<b>Dated</b>	<b>Acknowledge Receipt (Please Initial)</b>
#2	2/13/2023	_____

Acknowledged on behalf of:

\_\_\_\_\_  
(Name of Respondent)

By:

\_\_\_\_\_  
(Signature of Authorized Representative)

Name: \_\_\_\_\_

Title: \_\_\_\_\_

Date: \_\_\_\_\_





## **ADDENDUM #2**

### **Clarification Item #1**

Bidders are requested to provide two separate add alternate prices for the following scope:

1. Conceal all power and lighting distribution within the interiors of the walls and ceilings
2. Conceal all telecommunication distribution within the interiors of the walls and ceilings

For the avoidance of doubt, the intent for these two add alternates is to:

- Eliminate all surface mounted wire-mold and surface mounted boxes/devices
- Provide conduit in lieu of wire mold for distribution of electrical power and lighting
- Channel walls and ceilings to conceal all raceways, boxes, wiring and devices and patch wall accordingly
- Account for any lead containing paint and/or lead based paint in work
- Provide conduit in lieu of wire mold for distribution of electrical power, lighting and communications, as specified in items (1) and (2) above

